



PUBLIC SWIMMING POOL INSPECTION REPORT

Facility Name: Sugar Hill Fountain
 Facility Address: 5099 West Broad Street
 Permit Number: 00751586 Trained Operator's Name: Linton A McQuagge
 Inspection Date: 7-18-18 Time In: 9:45A 533185 9-13-21
 Pool Location: Indoor Outdoor Both Time Out: 10:30 Req. Disinfectant Level: 1 ppm
 Water Source: Public Well

RATING	
<input checked="" type="checkbox"/>	SATISFACTORY
<input type="checkbox"/>	UNSATISFACTORY

Critical violations denote imminent health hazards commonly reported as contributing factors in waterborne illness and injury investigations. The pool must be closed until imminent health hazards are corrected.

	Descriptions	Item	IN	OUT	COS	R
CRITICAL VIOLATIONS	Barrier: pool enclosed/fencing in compliance	1	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Self-closing / self-latching gates	2	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Compliant drain covers in place and in good condition	3	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Vacuum line protected / entrapment hazards not present	4	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Glass / cutting hazards not present	5	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Water clarity: main drains clearly visible	6	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Proper disinfectant level	7	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	pH between 7.2 and 7.8	8	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Chemical feeder operational	9	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Filter: maintained and operating	10	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Pump: maintained and operating	11	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Descriptions	Item	OUT	N/A	COS	R
POOL/SPA AREA & WATER SAFETY	Grab/hand rails, ladders installed and secure	12	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Float line in position	13	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Emergency phone available	14	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Depth and no diving markers, step marking; installed and contrasting	15	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Pool / Pool deck: maintained, unobstructed and clean	16	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Skimmers/gutters maintained and operable	17	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Return inlets maintained	18	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Alkalinity between 60-180 ppm	19	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Combined chlorine level 0.4 ppm or less	20	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Cyanuric acid level not exceeding maximum	21	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Water temperature does not exceed 104F	22	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
EQUIPMENT	Appropriate lifesaving equipment present	23	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Piping identified and marked	24	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Pump strainer: basket cleanable	25	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Flow meter / gauge(s) operational	26	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Adequate test kit on-site	27	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Automated controller operational; pumps interlocked	28	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Supplemental disinfection <input type="checkbox"/> UV system, <input type="checkbox"/> Ozone system	29	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
HYGIENE FACILITIES	Toilets & lavatories: clean and maintained	30	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Deck / rinse shower maintained if present	31	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Dressing showers: clean and maintained	32	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
RECORDS	Operator training certification available onsite and approved	33	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Certified pool operator's contact information posted	34	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Lifeguard training certification available onsite	35	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Inspection report placed in public view	36	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
	Signs: pool/spa/signs legible and in clearview	37	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Other violations of the chapter	38	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	

Permit Type	
Year Round	<input type="checkbox"/>
Seasonal	<input checked="" type="checkbox"/>
Inspection Purpose	
Construction	<input type="checkbox"/>
Permit / Opening	<input type="checkbox"/>
Routine	<input checked="" type="checkbox"/>
Follow-Up	<input type="checkbox"/>
Informal	<input type="checkbox"/>
Complaint	<input type="checkbox"/>
Pool Type	
Swimming Pool	<input type="checkbox"/>
Spa	<input type="checkbox"/>
Special Purpose Pool	<input type="checkbox"/>
Special Purpose Type: <u>Fountain</u>	
Water Quality and Gauge Readings	
Free Chlorine	<u>3</u> ppm
Bromine	ppm
pH	<u>7.4</u>
Total Alkalinity	<u>60</u> ppm
Cyanuric Acid	ppm
Water Temperature	°F
Flow Meter	gpm
Pressure Gauge	psi
Cyanuric Acid	ppm
Water Temperature	°F
Flow Meter	gpm
Pressure Gauge	psi
Compliance Closure	
Voluntary	<input type="checkbox"/>
Suspension	<input type="checkbox"/>
Request Hearing	<input type="checkbox"/>
Require Inspection	<input type="checkbox"/>

Remarks/Notes: Questions? 770-963-5130

36. Pool inspection report not posted for public view.

Contact 770 831 7413

Inspector: MUP
Signature: [Signature]

Person In Charge: [Signature]
Signature: Matt Phillips