



ADDENDUM NO. 1

CITY OF SUGAR HILL, GEORGIA SUGAR HILL PIB GREENWAY TRAIL REALIGNMENT

ADDENDUM DATE: FEBRUARY 13, 2020

BELOW ARE ITEMS THAT CREATE AN AMENDMENT TO THE CONTRACT DOCUMENTS FOR THE PROJECT LISTED ABOVE:

ITEM NO. 1:

Under Part I, Section III, the Bid Form shall be replaced with the Bid Form attached to this Addendum.

ITEM NO. 2:

Under Part I, Section I – Article 7 – Interpretation and Clarifications, the deadline for submitting all questions about the meaning or intent of the Bidding Documents in writing will be 2:00 PM on Friday, February 21, 2020. Responses to the written questions will be issued as Addendum No. 2 by 5:00 PM on Monday, February 24, 2020.

ITEM NO. 3:

Under Part I, Section I – Article 15.04 – the deadline for submitting the Bid Package will be 2:00 PM on Thursday, February 27, 2020.

ITEM NO. 4:

The following is a list of all written questions received prior to the 12:00 PM, July 12, 2019 deadline established in the Contract Documents and the formal response to those questions.

Question: The Bid Form does not have a line item for Type 1 and Type 12 Guardrail Anchors. Will these be added to the Bid Item List?

Response: The list of Bid Items has been revised to include these items.

Question: Is the sidewalk thickness 4 inch or 5 inch thick sidewalk?

Response: 5' sidewalk is 4" thick (3000 psi), 10' trail section is 5" thick (4000 psi).

Question: Will the self-leveling caulk be required to cover all expansion joint? If so, how will it be paid for?

Response: Yes, a Bid Item will be added.

Question: Will there be a line item for Saw Cutting the Asphalt for new C&G?

Response: Saw cutting will be included in the LF price for new curb & gutter.

Question: Will there be any Sod on this project?

Response: No sod on project. M-10 under guardrail.

Question: Who will apply and pay for the NOI?

Response: The City/Falcon Design will obtain the NOI for the project.

Question: Gwinnett DOT requires a Traffic Control supervisor on site or within 45 minutes of site. Will Sugar Hill require this?

Response: Yes, these roads are under GCDOT jurisdiction, so GCDOT requirements are to be met.

Question: Will a GSWCC Blue Card holder be required to be on site at all times?

Response: Compliance with NPDES permit is required for site supervision.

Question: Will there be any DBE Goals or Davis Bacon wages on this project?

Response: No DBE goals, no DB wages required.

Question: Erosion Control drawings 54-13 to 54-18 calls for DS3 and DS4 installation for all disturbed areas. However for DS4 (Sodding) there is no pay line item. Can you add a pay line item for Sod?

Response: No sod on project.

Question: There are no guardrail anchors shown on the drawings or in the bid items, they have to be there on Peachtree Industrial.

Response: Anchors are being added to the revised plan sheets.

Question: The guardrail is being installed in a 2ft beauty strip in all three locations, there is not enough room for the Type 12 anchors in those areas without modifications to the sidewalks.

Response: Sidewalk is being adjusted accordingly in revised plan sheets.

Question: There are no stations shown on the drawing sheet 13-05.

Response: Sheet 13-05 has been revised to show stations.

Question: Plans show existing rail to remain from sta. 25+16 to sta 32+65 shown on sheet 13-05 & 13-06 also shown on cross sections sheet 23-11 through 23+13 when the sidewalk is installed all of that rail will then be to low and will not meet standards.

Response: Plans have been revised to show new guardrail being installed in front of old guardrail. Old guardrail will remain in place where it does not conflict with new construction.

Question: The bid schedule does not have a line item for either the Inlet Sediment traps or the Curb Inlet Sediment Traps. Do I need to include them in my proposal? Usually GDOT does not pay non bid schedule items.

Response: SOQ has been revised to include inlet sediment traps.

Question: Guardrail from Sta: 1+32.03 to 3+66.39, does not show any guardrail anchor or terminal. Please specify guardrail anchorage type and clarify what pay line item it will be paid under.

Response: Guardrail terminals have been added to the plans and Bid Item list.

Questions: Drawing 16-01 calls for removal of section of existing guardrail at back of existing sidewalk and end of turndown wall sidewalk. Please specify new guardrail terminal end clarify what pay line item will be paid under?

Response: A type 1 terminal end has been added for guardrail being removed and added to SOQ.

Question: Per Typical Section Detail sht. 5-02 for all sidewalk turndown wall is to get handrail. Per notes on detail only powder coating cost for handrail to be paid under Galv. Steel pipe handrail.

Response: The handrail for the turndown sidewalk wall will be included in the Galv. Handrail quantity. All handrail will be galvanized, no black powder coat.

Question: Please clarify if drainage structure C-1 shall be catch basin 1033D (per Drainage Profile 22-01) to drop Inlet per sht. 6-01 and 13-03.

Response: Structure C-1 is a 1019A type E w/Hood.

Question: Please clarify sidewalk thickness for Turn-Up and Turn-Down sidewalk wall sections, the detail is not legible.

Response: Thickness for Sidewalk portion of Turn-Up and Turn-Down sidewalk wall sections is 6" thick..

ITEM NO. 5:

The following is a list of all plan sheets that have been revised in response to questions: 2-01, 3-01, 5-02, 6-01, 13-01, 13-02, 13-03, 13-05, 13-06, 16-01, 22-01, 23-05, 23-11, 23-12, 23-13, 24-05, 24-06, 26-05, 26-06, 54-11, 54-12, 54-17, and 54-18. These revised sheets are available for download in the project Dropbox folder as PDF Documents titled "TRAIL REALIGNMENT ADDENDUM 1.pdf". All attendees to the Pre-Bid will be emailed a link to the revised plan sheets.

ITEM NO. 6:

The City of Sugar Hill is adding the plans for "Whitehead Road Sidewalks @ Level Creek Bridge Area" to this Bid Package. The pdf plan set titled "WHR SIDEWALKS BRIDGE AREA PLANS.pdf" is available for download in the project Dropbox folder. All attendees to the Pre-Bid will be emailed a link to the plan sheets. All items in this plan set have been added to the Bid Form in Section III.

END ADDENDUM NO: 1



SIGNED: _____

DATE: February 13, 2020

Sean Paul Hayes, P.E.
Falcon Design Consultants, LLC