

ADDENDUM NO. 2
SUGAR HILL GREENWAY – PHASE 1
PROJECT NO. 20-014
CITY OF SUGAR HILL, GEORGIA

*Bids to be received until 2:00 p.m., local time, **June 25, 2020** (Revised)*

DRAWINGS

SPECIFICATIONS

BIDDER QUESTIONS

Sugar Hill Greenway Phase I - Bidder Questions No. 2:

1. Sheet PT03 – Boardwalk Abutments # 5 thru # 9 are designated with (*) Note: “Indicates cast-in-place wing walls and/or grade beams by others, See Civil Drawings.” We have reviewed the Civil Drawings and cannot find any design criteria for Boardwalk Abutments. Please provide abutment design criteria for Boardwalks # 5 thru # 9. We acknowledge the four (4) Structural Drawings, but none of them relate to Boardwalk abutments.

Response: The termination points for the boardwalk at grade will utilize the precast grade beam by PermaTrak. The connections of the boardwalk to the bridges will be as per the structural details.

End of Questions

Bidder Must Acknowledge Receipt of this Addendum on Bid Form

Jacobs Engineering Group
10 Tenth Street, Suite 1400
Atlanta, Georgia 30309
404 978-7439