



CITY OF SUGAR HILL

## IFB # 17-003 – ROADWAY IMPROVEMENTS ON VARIOUS CITY ROADS

*January 9, 2023*

### ADDENDUM #2

---

TO ALL BIDDERS: This addendum is issued for the purposes of modifying the original Bid, through addition, deletion, clarification or correction as outlined herein. The information provided in this addendum supersedes any information previously provided in the referenced document(s). This addendum and the information contained herein shall be used in the preparation of any bid submitted by the Bidder and shall become an integral part of the contract documents for any contract awarded for the project specified. Please inform all concerned that the Request is modified by this Addendum.

#### QUESTIONS:

1. Will portable tripod signs for low soft shoulders be okay or will post mounted signs be needed?  
A Tripods are acceptable.
2. What is the depth for the 19MM patching item on the bid schedule?  
A Patching depth will vary from street to street, but should include replacement of the entire asphalt section to the resurfacing elevation.
3. Are the manhole and water valve adjustments just risers or will we need to get concrete collar pricing for those bid schedule items?  
A Risers are acceptable.
4. When will the project be awarded and when will the NTP be sent out?  
A Award is anticipated within 30 days, NTP within 60 days.

Troy Besseche, P.E.  
*Assistant City Manager*

END OF ADDENDUM #2  
IFB 23-003